

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 7135-0587:120

Page 1 of 1

**CATEGORY:** Audible Signal Device

**LISTEE:** American Security Equipment Co., Division of Kobishi America Inc., 228 E. Star of India Lane, Carson CA 90746 Contact: Toby Tabata (310) 538-4670 Fax (310) 538-9932

**DESIGN:** Models MBA-6-12, MBA-8-12, MBA-10-12, MBA-6G-12, MBA-8G-12, & MBA-10G-12 audible devices (motorized bells). Refer to listee's data sheet for additional detailed product description and operational considerations..

**RATING:** 12 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical and audibility ratings and UL label.

**APPROVAL:** Listed as audible signal devices for use with separately listed compatible fire alarm control units. For indoor use. Models are intended for outdoor use when used with Model BBX-4 back box.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

12-18-02JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 24, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**